Babcock & Wilcox

a McDermott company

To

C. A. PALMBERG - PROJECT MANAGEMENT - BVCB3K

From

P. L. CIOFFI - MGR - COMBUSTION SYSTEMS - BVNO1C

BDS 663-8

Cust.

INTERMOUNTAIN POWER PROJECT

Subj.

IPP BURNER UPGRADES

Date

MAY 1, 1991

This letter to cover one customer and one subject only.

The following is a summary and description of the proposed modifications made to the dual register burners as shown on the attached sketch, SK41791E/0:

## Outer Air Register

- 1. Replaced outer air register with modified HD register.
- 2. Register front plate thickness increased from 1/2" to 5/8", material changed from carbon steel to 800H.
- 3. Register back plate thickness increased from 1/2" to 5/8", material changed from TP304 to 800H.
- 4. Center section of register back plate separated from register frame and attached with clips to allow for expansion.
- 5. Register door thickness increased from 10 ga. to 3/16", additional alloy stiffeners added to doors.
- 6. Added support legs (not shown on sketch) to register back plate.

## Throat Sleeve

- 7. Throat sleeve thickness increased from 1/4" to 3/8", material changed from TP304 to 800H.
- 8. Throat sleeve attached to register front plate with clips to allow for radial expansion.
- 9. Expansion ring added to throat sleeve OD (similar to S/EXCEL design).

## Slip Seal

10. Slip seal moved outboard on register front plate to eliminate interference with throat sleeve expansion. Seal arrangement reversed to minimize radiant heat on rope packing.